



BUILDING AND FIRE SAFETY

Fire Alarm Plan Submittal Checklist

Plans, specifications, calculations shall be of substantial detail to clearly indicate compliance with the California Fire/Building Code and NFPA 72. The following information is required to be included on all plan submittals:

- (1) Address of the protected premises
- (2) Owner of the protected premises
- (3) Responsible Alarm Contractor or Engineer
- (4) Applicable codes, standards, and other design criteria to which the system is required to comply
- (5) Type of building construction and occupancy
- (6) Fire department response point(s) and annunciator location(s)
- (7) Type of fire alarm system to be provided
- (8) Calculations (e.g., secondary supply and voltage drop calculations)
- (9) Type(s) of fire alarm-initiating devices, supervisory alarm-initiating devices, and evacuation notification appliances to be provided
- (10) Intended area(s) of coverage
- (11) Complete list of detection, evacuation signaling, and annunciator zones
- (12) Complete list of fire safety control functions
- (13) Complete sequence of operations detailing all inputs and outputs
- (14) Adequate floor and site plans indicating placement of appliances and controls
- (15) Raceway, wiring, termination boxes, controls and similar device types and locations.
- (16) Plans shall be of substantial detail and clarity to show compliance with the California Fire Code and NFPA 72

*Additional information may be required depending upon the occupancy or hazard.

