



**RFQ No. 2874 – Inspection and Cleaning of Water Reservoir
ADDENDUM NO. 1**

**Bid Closing is May 10, 2018 2p.m.
THE DATE TODAY IS: Tuesday, May 1, 2018**

Please note the following changes, additions and/or deletions to this procurement named above.

The following questions relative to RFQ No. 2874 have been received by our office and responses are as outlined below:

1. Is there more than one reservoir for this bid? *There is only one reservoir at this time.*
2. Is the interior lined or have an interior coating? *There is not a lining or coating.*
3. Are we asking for ACDE or ADCI (Association of Diving Contractors International) compliance *I don't know. We have always asked simply for Certified Divers for Diving Drinking Water Tanks.*
4. Do we require the NDPES Permit? *One has not been issued for the cleaning of any of the four tanks in the past.*
5. What permits are specifically required? *None have been issued by the City in the past. Unless something has changed that I do not know of, I expect again no permits.*
6. Is there anything we should know about the amount of debris that is in this tank or can you tell me why it might take additional time to remove the debris? *Tank receives a dive inspection every 3 years. Typically there has been just a light layer of sediment on the tank bottom.*
7. Do you have any idea what type of debris is in the tank? *See number 6 above*
8. Do you have any photos you would send me on the debris? *No. See number 6 above*
9. Are you considering debris as sediment? *See number 6 above*
10. Are requiring sediment bags to be used? *Not at this reservoir.*
11. Where will the discharge be released? Into a drain, and if so how far away is the drain from the tank? Or on the ground near the tank? *There is a v ditch within about 5 feet of the tank perimeters north side that drains to a dirt drainage area that merges with a larger dirt drainage area further down.*

This addendum may be returned separately from **RFQ No. 2874 – Inspection and Cleaning of Water Reservoir**. Addendum may be faxed to (805) 735-7628.

Thank you,

Theresa Hernandez

Buyer/ Purchasing Assistant/ Warehouse

Purchasing Division

1300 West Laurel Avenue Bldg. 4A, Lompoc CA 93436 • 100 Civic Center
Plaza Lompoc, CA 93436 Phone: (805) 875-8020 • FAX: (805) 735-7628
www.cityoflompop.com



**RFQ No. 2874 – Inspection and Cleaning of Water Reservoir
ADDENDUM NO. 1
Bid Closing is May 10, 2018 2p.m.**

Bidder's Acknowledgment: I/We the undersigned bidder hereby acknowledge this Addendum to RFQ No. 2874

(Please type or print)

COMPANY NAME

SIGNATURE OF AUTHORIZED REPRESENTATIVE

ADDRESS

AUTHORIZED REPRESENTATIVE (PLEASE PRINT)

CITY, STATE AND ZIP

TITLE

PHONE NUMBER

E-MAIL ADDRESS

FAX NUMBER

WEB PAGE ADDRESS

DATE

Purchasing Division

1300 West Laurel Avenue Bldg. 4A, Lompoc CA 93436 • 100 Civic Center
Plaza Lompoc, CA 93436 Phone: (805) 875-8020 • FAX: (805) 735-7628

www.cityoflompoc.com