



VALVE BOX &
8" PVC RISER

RSGV

MJ PIPE RESTRAINTS

MATERIAL per City of Lompoc
Standard Specifications & Details,
Section 4, II, G - Service Line Materials and Fittings

305mm (12") MIN.
760mm (30") MAX.

1' MINIMUM

CITY RIGHT OF WAY
PRIVATE PROPERTY

NOTE: ALL CROSS-CONNECTION CONTROL DEVICES MUST BE TESTED BY A CERTIFIED TESTER PRIOR TO FINAL INSPECTION.

455mm (18") MIN. CLEARANCE FROM NEAREST STRUCTURE

Drawing No. 404

CITY OF LOMPOC
Utility Department, Water Division

△	New drawing *404 reflecting vertical DCA similar to Febco Model 816V (revised August 2007)	KM	9/07
△	Added information for distance from Right of Way / Private Property Line.	KM	6/08
MARK	REVISIONS	APPR.	DATE

3" - 12" VERTICAL CROSS-CONNECTION CONTROL WET FIRE SPRINKLER SYSTEM WITH FIRE DEPARTMENT CONNECTION

RESOLUTION NO. 5008(02)

SHEET 1 OF 1