



NOTE:  
Connections between Meter  
and Backflow Assembly  
are not permitted.

Same as other end.  
3" Companion Flg with 2" I.P. Tap  
Ford BII-777W with Lock-wing

Ford P.J. for I.P. C55-77 or Ford C85-77  
Optional method requires Brass Pipe  
to be threaded at both ends.

Pack Joint Coupling Ford C85-77 or C55-77  
NOTE: Utilizing P.J. couplings on each end,  
brass pipe doesn't require to be threaded

NOTES:  
All valves 3" through 12" will be RSVG (Resilient Seat Gate Valves). Valves shall be Mueller or approved equal with Non-rising Stem, with either 2" operating nut or hand wheel. Use brass bolts on meter flanges. All other bolts and nuts are to be low carbon steel and conform to ASTM A 307 GRADE.

<b>Drawing No. 409</b>			
MARK	REVISIONS	APPR.	DATE

**CITY OF LOMPOC**  
Utility Department, Water Division

**3" METER WITH BY-PASS**

RESOLUTION NO. 5008(02) SHEET 1 OF 1