



NOTE:  
Connections between Meter and Backflow Assembly are not permitted.

NOTES:

All valves 3" through 12" will be RSGV (Resilient Seat Gate Valves). Valves shall be Mueller or approved equal with Non-rising Stem, with either 2" operating nut or hand wheel. Use brass bolts on meter flanges. All other bolts and nuts are to be low carbon steel and conform to ASTM A 307 GRADE.

Drawing No. 410-4

CITY OF LOMPOC  
Utility Department, Water Division

---	Drawing 410 split into 410-4 & 410-5 for separate 4' & 6'	KM	9/07

4" METER WITH BY-PASS